

Town of North Haven - Security Surveillance Fire HQ - #19-12
Addendum #2

- Will a rack and power within the rack be provided for the switch and NVR. If not, how do you want the switch and NVR mounted?

Power and a rack will be provided by the Town

- What type of RAID storage do you want in the NVR?

Tier 1

- 6 mega-pixel cameras seem overkill on the three indoor office cameras when 2 mega-pixel is sufficient for such a small space to cover. Is this acceptable for those three cameras?

The three interior cameras located within the fire station itself can be minimum of 4 mega-pixel cameras however must continue to have night vision

- It also states that all cameras must be outdoor rated. Even the indoor office cameras?

The three interior cameras located within the fire station itself do not need to be outdoor rated. The four interior cameras located in the apparatus bays of must be outdoor rated due to varying temperature environments.

- You are very specific about a 2.8mm lens on the cameras. While this may be proper for most of the exterior cameras, it may not be for the interior ones or outdoor ones that look down the building narrowly (west side). Can we be flexible on the lens size or do vari-focal lenses?

Vari-focal lenses are acceptable

- In doing the research for a 6 MP camera (which seemed like an odd number), I determined that none of the 'mainstream' camera manufacturers have any, 5 MP is the standard for that high of quality. I then noticed that HIKVision has a 6 MP camera w/ 2.8 mm lens as you specify, which is where you got the spec I imagine. The problem is that HIKVision has been banned by the Federal Government as of a month ago, none of their cameras can be sold or installed in any federal government facility or public or private 'critical infrastructure', it is a crime to do so. Any HIKVision cameras in the field in those facilities must be removed within two years. I respectfully suggest that you accept 5 MP cameras for which you will get great products. Please let me/us know if HIKVision is what was under the spec and if you still want that.

Where 6 MP cameras have been requested, 5 MP cameras will be sufficient. The cameras must still have night vision and a 2.8 mm lens and/or a vari-focal lens.